

EC-CERTIFICATE OF CONFORMITY
0761 – CPD – 0084

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to construction products (Construction Products Directive – CPD), amended by the Directive 93/68/EEC of the Council of the European Communities of 22 July 1993, it has been stated that the construction product

Powered smoke and heat exhaust ventilators
Axialventilator, type P- XR12JT5
diameter: 315 mm
Class F300

produced by the manufacturer

Witt & Sohn AG
Wuppermanstr. 6-10
D-25412 Pinneberg

in the factory

Pinneberg (D)

is submitted to factory production control. The notified body MPA Braunschweig (No. 0761) performed the initial type-testing of the product and an initial control of the factory production control. The notified body also carries out the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the attestation of conformity described in Annex ZA of the standard

EN 12101-3:2001-02


were applied and that the product meets all requirements addressed in this standard.

This certificate has first been issued on 2008-10-08. It remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the factory production control itself or the technical data on which this certificate is based are not modified significantly.

Braunschweig, 2008-11-17

ÜZ-3/682/02




Dr.-Ing. W. Hinrichs
Head of certification

Axial Smoke Exhaust Ventilator**1. Use and application classes**

The ventilator may be mounted as follows:

- outside of the building without thermal insulation
- outside of the building including thermal insulation
- inside the building but outside of the fire zone, without thermal insulation
- inside the building but outside of the fire zone including thermal insulation
- inside the fire zone without thermal insulation
- inside the fire zone including thermal insulation

The motor axle shall be orientated as follows:

- horizontal, floor standing
 - horizontal, wall mounted
 - horizontal, ceiling mounted
 - vertical, Δp upward
 - vertical, Δp downward
 - vertical, wall mounted
 - vertical, ceiling mounted
- The ventilator may be used for both functions.
- Cooling is necessary.

**2. Functioning time**

The test was finished after the ventilator had maintained its function for 136 min.

3. Technical product data

Hub ratio	N, M, X, Y
Diameter	315 mm
Direction of flow	reversible
Motor maker	Leroy Somer
Motor frame size	90S

4. Additional information

Standards referred to:

EN 12101-3	EN 13501-4	EN 1363-1	EN 1363-2	ENV 1363-3
------------	------------	-----------	-----------	------------

----- End of the EC-Certificate of conformity -----